## Notes: (A) Member Should reference NEC for Connection Requirements. (B) Disconnect Switch must be a break before make type switch. A closed transition is not allowed. TVEC Electrical System WITH GAS DRIVEN **METERED SITE** GENERATION Member's Electrical Panel Safety Switch **Double Throw** See Note TRINITY VALLEY ELECTRIC COOP. **Gas Driven** Generator Gas Generator

One Line Diagram